

#### General Notes & Guidance:

### General Waterproofing

All waterproofing details shown herein should be brought to the attention of the designer of the structure, who is responsible for the waterproofing and structural design and for being aware of all the factors in the structural design that may impact on the waterproofing details, and approved by them in writing. Final decisions and any recommendations must be approved by the

#### Roof Slabs / Podium Decks

This detail is for typical roof waterproofing applications only and may require modification to suit specific project conditions and design requirements. The design and application is to comply with the recommendations of BS 6229:2003 `Flat Roofs With Coninuously Supported Coverings'.

## Basements / Buried Decks

BS 8102:2009

6.2.4 The need for continuity in the waterproofing protection should also be considered when selecting a type of protection. In most circumstances, the protection should be continuous.

For product installation this drawing is to be read in conjunction with all relevant product data

# **Drawing Notes:**

Rev Date Description



**GCP APPLIED TECHNOLOGIES** 

580 / 581 Ipswich Road, Slough, Berkshire, SL1 4EQ, UK T: +44 (0) 1753 490000 E: info-gb@gcpat.com W: www.gcpat.com SILCOR, SLIPSTRIP, SOLARSHIELD, VERTISEAL, ZIPLAP and GCP APPLIED TECHNOLOGIES are trademarks which may be registered in the United States and/ or other countries, of GCP Applied Technologies Inc. This trademark list has been compiled using available published information as of the publication date and may not accurately reflect current trademark ownership or status. These products may be covered by patents or patents pending.

This drawing is Copyright 2019 of GCP Applied Technologies. Permission for copying is granted only to employees, authorised representatives, customers, and specifiers to support the sale or use of GCP Applied Technologies products. All other rights are reserved

STEEL BASE PLATE INTEGRITANK SYSTEM Additional Info:

Scale @ A4: NTS

Drawn: Checked:

Rev:

Drawing No: INT-19-20